

SERTIFIKAT O KONTROLISANJU
INSPECTION CERTIFICATE

Broj / Number: T 1305-1

Strana / Page: 1/2

Na zahtev naručioca /
By the request of purchaser: **Fondital S.p.A., 25079 Vobarno (BS), Italija /Italy**

preduzeto je/
set to: kontrolisanje novog proizvoda
the new product inspection

u vezi sa Izveštajem o kontrolisanju /
in relation to Inspection report:

Broj / Number: T 1305-1

sa dokumentima u prilogu/
with enclosed documents:

- Prospekt proizvoda /
Catalogue pages of product;
- Uputstvo za instaliranje i korišćenje /
Installation and user's manual;
- Dokumentacija o proizvodu /
Product documentation;
- Izveštaj o ispitivanju IMP-CGT-LAB broj T 1305 /
Test report by IMP-CGT-LAB No. T 1305.

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet kontrolisanja /
the inspection object: **GASNI KONDENZACIONI KOTAO**
GAS CONDENSING BOILER

proizveden od /
manufactured by: **Fondital S.p.A., Via Cerreto, 40**
25079 Vobarno (BS), Italija /Italy

oznaka - tip - serija /
mark - type - series: **FONDITAL ANTEA...**

vrsta/type: B₂₃, C₁₃, C₃₃
kategorija/category: II_{2H3P}

kako je specificirano u Prilogu A, zadovoljava zahteve navedene u /
as specified in the Annex A, meets the requirements listed in:

referentnom dokumentu /
reference document: **SRPS EN 483:2010; SRPS EN 625:2011;**
SRPS EN 677:2011.

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2002.
The inspection certificate is issued basis on the standard SRPS ISO/IEC 17020:2002.

Nadzor usaglašenosti predmeta kontrolisanja se obezbeđuje sa periodičnim
kontrolisanjem do dana /
Surveillance of the inspection object compliance is assured by periodical
inspection until the date:

22.01.2018.

mesto, datum / place, date:

Beograd, 23.01.2013.

izdat od / issued by:

RUKOVODILAC CENTRA ZA GASNU TEHNIKU

GAS TECHNIQUE CENTRE MANAGER

Vučko Markidević, dipl. ing.

Ime, Prezime / Name, Surname



SERTIFIKAT O KONTROLISANJU
INSPECTION CERTIFICATE

Broj / Number: T 1305-1

Strana / Page: 2/2

Prilog A /
Annex A

oznaka - tip - serija /
mark - type - series :

FONDITAL ANTEA...

vrsta/type: B₂₃, C₁₃, C₃₃
kategorija/category: П_{2H3P}

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :	
FONDITAL ANTEA...			
...KC 24	Q _n =3,0÷23,7 kW P _n =2,7÷22,9 kW	2H: p=20 mbar 3P: p=37 mbar PMS=3 bar, Ts=83° C,	- za grejanje i pripremu tople sanitarne vode (TSV) / for heating and preparation of domestic hot water (DHW)
...KC 28	Q _n =3,3÷26,4 kW P _n =3,0÷25,4 kW	PMW= 8 bar, IPX4D 230V, 50 Hz	

Inspection certificate

Sertifikat o kontrolisanju