



ATC  
06-010

АКРЕДИТОВАНА  
КОНТРОЛНА  
ОРГАНИЗАЦИЈА

SRPS ISO/IEC 17020:2002

**SERTIFIKAT O KONTROLISANJU**  
**INSPECTION CERTIFICATE**

Broj / Number:

T 1034

Strana / Page:

1/2

**Na zahtev naručioca /**  
*By the request of purchaser:*

**Robert Bosch d.o.o. ;** Milutina Milankovića 11a ; Beograd  
Srbija/Serbia

**preduzeto je/**  
*set to:*

kontrolisanje novog proizvoda  
*the new product inspection*

**u vezi sa Izveštajem o kontrolisanju /**  
*in relation to Inspection report:*

Broj / Number:

T 1034

**sa dokumentima u prilogu/**  
*with enclosed documents:*

- Prospekt proizvoda /  
*Catalogue pages of product;*
- Uputstvo za instaliranje i korišćenje /  
*Installation and user's manual;*
- Izveštaj o ispitivanju IMP-CGT-LAB broj T 1034 /  
*Test report by IMP-CGT-LAB No. T 1034*

**INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:**  
*INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:*

**predmet kontrolisanja /**  
*the inspection object :*

**GASNI KONDENZACIONI KOTAO**  
**GAS CONDENSING BOILER**

**proizveden od /**  
*manufactured by :*

**Bosch Thermotechnik GmbH**

**oznaka - tip - serija /**  
*mark - type - series :*

**BOSCH CONDENS 5000 W ZBR ...**

*vrsta/type: B<sub>23(P)</sub>, C<sub>13(X)</sub>, C<sub>33(X)</sub>, C<sub>43(X)</sub>, C<sub>53(X)</sub>*  
*kategorija/category: II<sub>2H3P</sub>*

**kako je specificirano u Prilogu A, zadovoljava zahteve navedene u /**  
*as specified in the Annex A, meets the requirements sa decribed in :*

**referentnom dokumentu /**  
*reference document :*

**SRPS M.E.6.300:1994; EN 483:1999; EN 677:1998**

**Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2002 .**  
*The inspection certificate is issued basis on the standard SRPS ISO/IEC 17020:2002 .*

**Nadzor usaglašenosti predmeta kontrolisanja se obezbeđuje sa**  
**periodičnim kontrolisanjem do dana /**

*Surveillance of the inspection object compliance is assured by periodical*  
*inspection until the date :*

01.11.2015

INSTITUT  
"MIHAJLO PUPIN"  
CENTAR ZA  
GASNU TEHNIKU  
Volgina 15  
BEOGRAD  
SRBIJA  
tel: +381 11 2772 151  
fax: +381 11 2781 029  
impcgt@labtel.imp.bg.ac.rs



**izdat od / issued by :**

**za RUKOVODIOCA CENTRA ZA GASNU TEHNIKU**  
*instead of the GAS TECHNIQUE CENTRE MANAGER*

**mesto, datum / place, date**  
Beograd, 02.11.2010

**M.P.A.D.**  
**S.P.**

Dejan Simonović, dipl. ing.

Ime , Prezime / Name , Surname



**SERTIFIKAT O KONTROLISANJU**  
**INSPECTION CERTIFICATE**

Broj / Number: **T 1034**  
 Strana / Page: **2/2**

**Prilog A /**  
**Annex A**

**oznaka - tip - serija /**  
**mark - type - series :**

**BOSCH CONDENS 5000 W ZBR ...**

vrsta/type: **B<sub>23(P)</sub>, C<sub>13(X)</sub>, C<sub>33(X)</sub>, C<sub>43(X)</sub>, C<sub>53(X)</sub>**  
 kategorija/category: **II<sub>2H3P</sub>**

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :
<b>BOSCH CONDENS 5000 W</b>		
<b>ZBR 65-2</b>	2H: p=20 mbar $Q_n=14,6\div 62,0$ kW (Hi) $P_n=14,2\div 60,4$ kW <sup>1.)</sup> PMS=4 bar, T=90°C 3P: p=50 mbar 230 V, 50 Hz, IP X4D , IP X0D <sup>2.)</sup> NO <sub>x</sub> : 5 , η : ★★★★★	zidni gasni kondenzacioni kotao- / wall hung gas condensing boiler -
<b>98-2</b>	2H: p=20 mbar $Q_n=19,3\div 95,0$ kW (Hi) $P_n=18,6\div 92,1$ kW <sup>1.)</sup> PMS=4 bar, T=90°C 3P: p=50 mbar 230 V, 50 Hz, IP X4D , IP X0D <sup>2.)</sup> NO <sub>x</sub> : 5 , η : ★★★★★	
Napomene / notes: 1.) pri / at: t <sub>2</sub> /t <sub>1</sub> =80/60°C; 2.) samo za / only for: B <sub>23(P)</sub> .		

**Sertifikat o kontrolisanju**  
**Inspection certificate**