



SERTIFIKAT O KONTROLISANJU
INSPECTION CERTIFICATE

Broj / Number: T 1031

Strana / Page: 1/2

Na zahtev naručioca /
By the request of purchaser:

Robert Bosch d.o.o. ; Milutina Milankovića 11a ; Beograd
Srbija/Serbia

preduzeto je/
set to:

kontrolisanje novog proizvoda
the new product inspection

u vezi sa Izveštajem o kontrolisanju /
in relation to Inspection report.

Broj / Number: T 1031

sa dokumentima u prilogu/
with enclosed documents:

- Prospekt proizvoda /
Catalogue pages of product;
- Uputstvo za instaliranje i korišćenje /
Installation and user's manual;
- Izveštaj o ispitivanju IMP-CGT-LAB broj T 1031 /
Test report by IMP-CGT-LAB No. T 1031

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet kontrolisanja /
the inspection object :

GASNI KOTAO
GAS BOILER

proizveden od /
manufactured by :

Bosch Thermotechnik GmbH

oznaka - tip - serija /
mark - type - series :

BOSCH GAZ 3000 W1^{1.)} ZS 23-1 LH KE ...
OS 23-1 LH KE ...
ZW 23-1 LH KE ...
OW 23-1 LH KE ...

Napomena / Note :

1.) Označenje ...W1... je primenjena komercijalna oznaka u Srbiji umesto ...W... / *Designation ...W1... is used commercial code in Serbia instead of ...W...*

vrsta/type: **B_{11BS}**

kategoriya/category: **II_{2H3B/P}**

kako je specificirano u Prilogu A, zadovoljava zahteve navedene u /
as specified in the Annex A, meets the requirements sa described in :

referentnom dokumentu /
reference document :

EN 297:1994 ; SRPS EN 625:1999

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2002 .
The inspection certificate is issued basis on the standard SRPS ISO/IEC 17020:2002 .

Nadzor usaglašenosti predmeta kontrolisanja se obezbeđuje sa
periodičnim kontrolisanjem do dana /

Surveillance of the inspection object compliance is assured by periodical inspection until the date :

11.10.2015

izdat od / issued by :

RUKOVODILAC CENTRA ZA GASNU TEHNIKU

GAS TECHNIQUE CENTRE MANAGER

Mr. Vladeta Buljak, dipl. ing.

mesto, datum / place, date :

M.P. /
S.P.

Beograd, 12.10.2010

Time, Prezime / Name, Surname

Inspection certificate

Sertifikat o kontrolisanju

SERTIFIKAT O KONTROLISANJU
INSPECTION CERTIFICATE

Broj / Number:

T 1031

Strana / Page:

2/2

Prilog A /

Annex A

oznaka - tip - serija /

mark - type - series :

BOSCH GAZ 3000 W1^{1.)}

ZS 23-1 LH KE ...

OS 23-1 LH KE ...

ZW 23-1 LH KE ...

OW 23-1 LH KE ...

vrsta/type: **B_{11BS}**

kategorija/category: **II_{2H3B/P}**

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :
BOSCH GAZ 3000 W1^{1.)} ...		
ZS 23-1 LH KE 23	2H: p=20 mbar 31 3B/P: p=30 mbar	zidni gasni kotao sa pripremom tople sanitarne vode u rezervoaru koji nije deo proizvoda- / wall hung gas boiler with domestic hot water preparation in a tank which is not a part of the product
	$Q_n=9,3 (8,4)^{2.}) \div 25,3 \text{ kW (Hi)}$ $P_n=8,0 (7,0)^{2.}) \div 22,6 \text{ kW}$ PMS=3 bar, T=90°C	
OS 23-1 LH KE 23	2H: p=20 mbar 31 3B/P: p=30 mbar	zidni gasni kotao sa protočnom pripremom tople sanitarne vode u izmenjivaču van kruga sagorelih gasova- / wall hung gas boiler with flow preparation of domestic hot water in the exchanger out of the flue gas circuit
	230 V, 50 Hz, IP X4D NO _x : 1 η : ★★	
ZW 23-1 LH KE 23	2H: p=20 mbar 31 3B/P: p=30 mbar	zidni gasni kotao sa protočnom pripremom tople sanitarne vode u izmenjivaču van kruga sagorelih gasova- / wall hung gas boiler with flow preparation of domestic hot water in the exchanger out of the flue gas circuit
	$Q_n=9,3 (8,4)^{2.}) \div 25,3 \text{ kW (Hi)}$ $P_n=8,0 (7,0)^{2.}) \div 22,6 \text{ kW}$ PMS=3 bar, T=90°C	
OW 23-1 LH KE 23	2H: p=20 mbar 31 3B/P: p=30 mbar	zidni gasni kotao sa protočnom pripremom tople sanitarne vode u izmenjivaču van kruga sagorelih gasova- / wall hung gas boiler with flow preparation of domestic hot water in the exchanger out of the flue gas circuit
	230 V, 50 Hz, IP X4D NO _x : 1 η : ★★	
Napomene/ notes:	1.) Označenje ...W1... je primenjena komercijalna oznaka u Srbiji umesto ...W... / Designation ...W1... is used commercial code in Serbia instead of ...W... 2.) karakteristike u zagradi za pripremu tople sanitarne vode ukoliko se razlikuju od karakteristika za grejanje/ characteristics in brackets for domestic hot water preparation if they are different than characteristics for heating	

Sertifikat o kontrolisanju
Inspection certificate